Water Operators Report June. 2025

Prepared by: Dave Shepherd

| Prepared by. Dave Si | ieprieru | | | | | | |
|------------------------------|--------------------------|---------------------|--------------|-----------------------|---------------|-----------|--|
| | , | Water consum | ption | | | | |
| Monthly Consumption | 15,369.00 M ³ | | 512.30 N | 1 ³ | Daily Average | | |
| Previous year 2024-June | 12,949 M ³ | 28 | 462.46 N | 1 ³ | Daily Average | | |
| Vol Well #1 since 19 Jan 201 | 361.77 M ³ | | | | Last month | Last year | |
| Max Flow for month | 1,746.20 L/Min | Min Flow for m | onth L/Min | 4.4 | 0 | 15.1 | |
| Time and Date | 11:58 10th June | June 19:49 3rd June | | | | | |
| Pump hours | # 2 140:24 | # 3 | 10:52 | #4 | 365:32 | | |
| Previous month hrs | 151 | | 4 | | 528 | | |
| VIHA Samples | | | | | | | |
| Activity Date | Location | Sample type | Result | | | | |
| Monthly 09/06/2025 | 7941 Park | Drinking water | ✓ | | | | |
| Sample /testing | 7588 Ships Pt. | Drinking water | \checkmark | ≰ | | | |
| | 7576 Tozer | Drinking water | ✓ | ⇟ | | | |
| | Well 2 | Raw | ✓ | t to VIHA | | | |

Operations/Maintenance

Weekly:

Well 3

Well 4

Meter readings, CL residuals (5 locations) incl flushing station, run pump 1 collect well levels data Check CL tank level and add accordingly

Monthly:

Prep chain of custody report and sample bottles Collect Island Health samples and deliver to office Collect end of month Data create report, replace CL membrane & order chlorine as needed Attend WTC and SPID Meetings

02/06/2025 Park Lane low pressure concern, tested PSI at Rd. and house Determined household filter plugged
03/06/2025 Meet JA at office re Stats Can survey and Water Dept Visa, Meet BC hydro at Pumphouse
06/06/2025 Comms with Nick (White Pacific re changed to PLC alarms during weekly flushing station operation

Raw

Raw

| 07/06/2025 | STAGE 2 water conservation implemented due to weekly consumption > 2500 LPM |
|------------|---|
| | Connect and test wild fire protection sprinkler |
| 09/06/2025 | Generator Test |
| 10/06/2025 | Nick (white Pacific) Mod program re #3 under performing. #4 to come on at 1000 LPM vs 1400 (was 1800) |
| 11/06/2025 | remind White Pacific re Vpn quote, go over SCADA report data from Nick |
| 12/06/2025 | Send Drill well #3 tag No. and pix of trees |
| 13/06/2025 | Remove screws from #3 roof to see if can be removed for Drillwell crane |
| 16/06/2025 | Go over IH system overview gather data |
| 30/06/2025 | Request 6 month IH sample report, Lock Baynes service box re Tolls to be paid as part of sale |
| | |