

Water Operators Report Feb. 2026

Prepared by: Dave Shepherd

Water consumption

Monthly Consumption	6,700 M ³		239.29 M ³	Daily Average
Previous year 2025-Feb.	5,275 M ³	28	188.38 M ³	Daily Average

Vol Well #1 since 19 Jan 2019	416.54 M ³			Last month	Last year
Max Flow for month	339.80 L/Min	Min Flow for month L/Min	62.6	52	12
Time and Date	21/02/2026 07:16		05/01/2026 01:04		
Pump hours	# 2 425h17m	# 3	0h41m	#4	249h44m
Previous month hrs	739h0m		48m		3h41m

VIHA Samples					
Activity	Date	Location	Sample type	Result	
Monthly Sample /testing	09/02/2026	7941 Park	Drinking water	✓	Sent to VIHA
		7588 Ships Pt.	Drinking water	✓	
		7576 Tozer	Drinking water	✓	
		Well 2	Raw	✓	
		Well 3	Raw	✓	
		Well 4	Raw	✓	

Operations/Maintenance

Weekly:

Meter readings, CL residuals (5 locations) incl flushing station, run pump 1 collect well levels data
Check CL tank level and add accordingly

Monthly:

Prep chain of custody report and sample bottles Collect Island Health samples and deliver to office
Collect end of month Data create report, replace CL membrane & order chlorine as needed
Attend WTC and SPID Meetings

01/02/2026	Call out Pumphouse Low CL Manually switch to CL pump #2 and prime
03/02/2026	Repair Chlorine leak in control room where high pressure flex hose connects to PVC
04/02/2026	Island Health Site inspection with Josh
06/02/2026	Complete IH annual report save copy to sync and send to IH
23/02/2026	3xPumphouse inspections completed by Island Rope
25/02/2026	Complete Draft AGM report

