

# Water Operators Report Aug 21 [\(water report Aug 2024.\)](#)

Prepared by: Dave Shepherd

## Water consumption

Monthly Consumption	12627.8 M <sup>3</sup>	28	450.99 M <sup>3</sup>	Daily Average
Previous year 2023-05	10843 M <sup>3</sup>	28	387.25 M <sup>3</sup>	Daily Average
<b><u>16.46%</u></b>				
Vol Well #1 since 19 Jan	330.3 M <sup>3</sup>			Last month Last year
Max Flow for month	1,983.90 L/Min	Flow for month L/Min	109.1	88.6 61.8
Time and Date	03/08/2024 07:04		03/06/2024 18:45	
Pump hours	# 2 672	# 3 87	#4 599	
Previous month hrs	490	143	550	

## VIHA Samples

Activity	Date	Location	Sample type	Result	
Monthly Sample /testing	08/07/2024	7941 Park	Drinking wa	✓	Sent to VIHA
		7588 Ships Pt.	Drinking wa	✓	
		7576 Tozer	Drinking wa	✓	
		Well 2	Raw	✓	
		Well 3	Raw	✓	
		Well 4	Raw	✓	

## Operations/Maintenance

### Weekly:

Meter readings, CL residuals (5 locations) incl flushing sta  
Check CL tank level and add accordingly

### Monthly:

Prep chain of custody report and sample bottles Collect \  
Collect end of month Data create report, replace CL mem  
Attend WTC and SPID Meetings

07/08/2024 Install new Guage guardon CL system, respond to before

12/08/2024 Add de chlorination pucks to discharge system Tozer rd

22/08/2024 Meet Chris Larson Culligan water on site