

## Water Operators Report Apr. 2025

Prepared by: Dave Shepherd

### Water consumption

Monthly Consumption	4972.22 M <sup>3</sup>	28	363.68 M <sup>3</sup>	Daily Average
Previous year 2024-Feb	5540 M <sup>3</sup>	28	338.04 M <sup>3</sup>	Daily Average
			<u>7.59%</u>	
Vol Well #1 since 19 Jan 2019	356.07 M <sup>3</sup>			
Max Flow for month	1,081.20 L/Min	Min Flow for month L/Min	9	0
Time and Date	01/04/2025 21:14		13/04/2025 12:35	
Pump hours	# 2 637	# 3 0	#4 57	
Previous month hrs	685	0	23	

### VIHA Samples

Activity	Date	Location	Sample type	Result	
Monthly	14/04/2025	7941 Park	Drinking water	✓	
Sample /testing		7588 Ships Pt.	Drinking water	✓	
		7576 Tozer	Drinking water	✓	
		Well 2	Raw	✓	
		Well 3	Raw	✓	
		Well 4	Raw	✓	

Sent to VIHA

### Operations/Maintenance

#### Weekly:

Meter readings, CL residuals (5 locations) incl flushing station, run pump 1 collect well levels data  
Check CL tank level and add accordingly

#### Monthly:

Prep chain of custody report and sample bottles Collect Island Health samples and deliver to office  
Collect end of month Data create report, replace CL membrane & order chlorine as needed  
Attend WTC and SPID Meetings

08/04/2025 Creat SOP water shut down  
10/04/2025 Call out Pumphouse Reset VFD (windy so likely power bump)  
11/04/2025 Comms with Nick White Pacific re PLC program parameters

15/04/2025 Go over call out alarms re PLC  
23/04/2025 Research Vendors and create Vendors list  
28/04/2025 Call before you dig Tozer  
30/04/2025 Meet Tyler ClearTech he Can supply P Tubes and CL reagent, will look into Eletrolyte and menbranes  
Set up an account and purchased 2 P Tubes ans 6 packs of reagent. Confirmed PLC install for 1st May