

Water Operators Report Mar. 2025

Prepared by: Dave Shepherd

Water consumption

Monthly Consumption	3707.91 M ³	28	363.68 M ³	Daily Average
Previous year 2024-Feb	4394 M ³	28	338.04 M ³	Daily Average
			<u>7.59%</u>	
Vol Well #1 since 19 Jan 2019	352.78 M ³			Last month Last year
Max Flow for month	1,415.90 L/Min	Min Flow for month L/Min	0	0 14.2
Time and Date	22/03/2025 07:30		24/03/2025 00:33	
Pump hours	# 2 685	# 3 0	#4 23	
Previous month hrs	669	1	3	

VIHA Samples

Activity	Date	Location	Sample type	Result	
Monthly	10/03/2025	7941 Park	Drinking water	✓	
Sample /testing		7588 Ships Pt.	Drinking water	✓	
		7576 Tozer	Drinking water	✓	
		Well 2	Raw	✓	
		Well 3	Raw	☒	
		Well 4	Raw	✓	
				Sent to VIHA	Not recorded over winter months

Operations/Maintenance

Weekly:

Meter readings, CL residuals (5 locations) incl flushing station, run pump 1 collect well levels data
Check CL tank level and add accordingly

Monthly:

Prep chain of custody report and sample bottles Collect Island Health samples and deliver to office
Collect end of month Data create report, replace CL membrane & order chlorine as needed
Attend WTC and SPID Meetings

03/03/2025 JL Agreed full load test for the back up generator okay

White Pacific confirmed April instal of PLC okay

07/03/2025 confirm vacant lot serve box locations

12/03/2025 SPR locate service line to Main for excavation (landscaping)
13/03/2025 Deliver shut off notices for 7 properties re servive box relocation scheduled 15th
14/03/2025 Repair small CL leak junction Flex hoae/Sched 80 pipe in Control room
Show John Moore around Pumphouse
15/03/2025 Scheduled shut off re service box relocation SPR
17/03/2025 Send Draft 2024 AGM report for review
BC one call Baynes, send picture of drawing
20/03/2025 Meeting re well levels MM,BT,DS
21/03/2025 Check Well Level sensors with MM
Email White Pacific re PLS #2 feet vs Meters
26/03/2025 Generator Full load test